



NOTES:

1. This drawing to be used as a supplement to the standard NC150N/200N wiring diagram and wiring notes.
2. The NC150N/200N provide only ancillary annunciation of fire signals.
3. The NC267 operates on +12 VDC, 0.12W Standby and 0.48 Operating. A separate power supply must be used.
4. Pendant/receiver in parallel w/patient station, places routine call.
5. Pendant/receiver in parallel w/smoke detector, places high priority call.
6. Stand-alone single call priority.

